



Europe & Asia
CAPLINQ Europe BV
Industrieweg 15^E
1566 JN Assendelft
The Netherlands
Tel: +31 (20) 893.2224

Americas
CAPLINQ Corporation
957 Snowshoe Crescent
Orléans, Ontario K1C 2Y3
Canada
Tel: +1 (613) 482.2215

Worldwide
www.caplinq.com
Email: info@caplinq.com



Certificate of Compliance – UL YELLOW CARD Declaration

Product Series: LINQSOL BCP-3502
Part Number: BCP-3502
Description: Low to Medium Voltage Bus Bar Coating Powder

Customers often ask if our products are Underwriters Laboratory (UL) Certified. The reason they ask this is that they, in turn, need to provide UL certification on their products to their customers. CAPLINQ understands this, but the costs of UL certification can easily run into the thousands of dollars.

To complicate this, UL certification is often done only on a single version of a product and needs to be retested for additional variations, including color, filler types, sizes, and minor modifications. Multiply this by the number of products that CAPLINQ offers, and the costs of UL-certifying every product become cost-prohibitive.

CAPLINQ has adopted a policy whereby the UL tests are done in-house according to the UL Certification standard listed and are submitted for UL Certification once a letter of intent to purchase is received.

Flammability	Nominal Value	Unit	Test Method	Result
UL Flame Rating			UL94 IEC 60695-11-10, -20	
0.5 mm, ALL	V-0	-		PASS
2 mm, ALL	V-0	-		PASS
Thermal	Nominal Value	Unit	Test Method	
RTI Elec			UL 746	
0.5 mm	130	°C		PASS
2.0 mm	130	°C		PASS
RTI Imp			UL 746	
0.5 mm	130	°C		PASS
2.0 mm	130	°C		PASS
RTI			UL 746	
0.5 mm	130	°C		PASS
2.0 mm	130	°C		PASS

Name of person responsible for declaration:
Title of person responsible for declaration:

Christopher Perabo
Business Development Director

Signature of person responsible:
Date:


June 28, 2024